



333 Main Street NW
 P.O. Box 388
 Elk River, MN 55330
 Phone: 763-441-7509
 Fax: 763-441-9176

LABORATORY TEST REPORT

29702

File #: 84122

Date/Time in Lab: 10/19/2023 1:45 PM

2912 28H AVE S
 MINNEAPOLIS

MN 55406

Unique Well #:

Ordered By: TECHTRON ENGINEERING

Sampled From: See Below

Sampled By: TECHTRON ENGINEERING

Date/Time Sampled: 10/19/2023 1000

Reason For Test: Lead Only

Sample Temp: 13.6 ° C


Legal:

Received on Ice: Yes

<u>NAME OF TEST</u>	<u>DATE & TIME OF ANALYSIS</u>	<u>RESULT</u>
TALL CAFETERIA WF	10/19/2023 1000	< 2.5 µg/L
SHORT CAFETERIA WF	10/19/2023 1000	< 2.5 µg/L
TALL STUDENT BATHROOM WF	10/19/2023 1000	< 2.5 µg/L
SHORT STUDENT BATHROOM WF	10/19/2023 1000	< 2.5 µg/L
TALL SUCCESS CLASSROOM WF	10/19/2023 1000	< 2.5 µg/L
SHORT SUCCESS CLASSROOM WF	10/19/2023 1000	< 2.5 µg/L
TALL GYM WF	10/19/2023 1000	< 2.5 µg/L
SHORT GYM WF	10/19/2023 1000	< 2.5 µg/L
TALL ELEVATOR WF	10/19/2023 1000	< 2.5 µg/L
SHORT ELEVATOR WF	10/19/2023 1000	< 2.5 µg/L
SECOND FLOOR BATHROOM BOTTLE FILLER	10/19/2023 1000	< 2.5 µg/L
TALL HIGH SCHOOL WF	10/19/2023 1000	< 2.5 µg/L
SHORT HIGH SCHOOL WF	10/19/2023 1000	< 2.5 µg/L

Notes: Lead (SM 3113 B-99) THE MAXIMUM CONTAMINATION LEVEL FOR LEAD IS 15 µg/L.

The test results are only indicative of the sample tested from the sample point on the date collected.
 This report must not be reproduced, except in full, without the written approval from Water Laboratories, Inc.
 Minnesota Certification# 027-141-110, Wisconsin Certification #399044470

Signature: 

Amount Billed:

Date Paid:

Amount Paid:

Date Completed: 10/23/2023



333 Main Street NW
P.O. Box 388
Elk River, MN 55330
Phone: 763-441-7509
Fax: 763-441-9176

Received By EK

Entered By EK

Edited By TJ